



Opening Date: 2019-05-09   
Closing Date: 2019-05-20   
Closing Time: 11:00

## INSTITUTION DETAILS

Institution Name: King Edward VIII hospital   
Province: KwaZulu-Natal  
Department or Entity: Department of Health  
Division or section: Central Supply Chain Management  
Place where goods / services is required: KING EDWARD VIII HOSPITAL VARIOUS DEPT  
Date Submitted: 2019-05-07 

## ITEM CATEGORY AND DETAILS

Quotation Number: ZNQ:  
KM 25/19  
Item Category: Services   
Item Description: SERVICING OF AIR-CON PLANTS 2019/2020 SEP SPEC ATTACHED  
\* QUOTATIONS TO BE HANDED OUT AFTER SITE MEETING

Quantity (if supplies) 3

## COMPULSORY BRIEFING SESSION / SITE VISIT

Select Type: Compulsory Briefing Session   
Date: 2019-05-24   
Time: 11:00  
Venue: KING EDWARD VIII HOSPITAL

QUOTES CAN BE COLLECTED FROM: KHULANI MTHEMBU

QUOTES SHOULD BE DELIVERED TO: KING EDWARD VIII HOSPITAL TENDOR BOX

## ENQUIRIES REGARDING THE ADVERT MAY BE DIRECTED TO:

Name: KHULANI MTHEMBU  
Email: KHULANI.MTHEMBU@KZNHEALTH.GOV.ZA  
Contact Number: 031 360 3440  
Finance Manager Name: MISS NOMDNDE NCOME

Finance Manager Signature:

  
No late quotes will be considered



**health**

Department:  
Health  
PROVINCE OF KWAZULU-NATAL

King Edward VIII Hospital  
Private Bag X 07  
CNR of Rick Turner & Sydney Rd  
Tel. (031) 360 3468; Fax. (031) 205 0207  
Email: [aizwe.gaxa@kzahhealth.gov.za](mailto:aizwe.gaxa@kzahhealth.gov.za)

**SPECIFICATION**

**TO**

**SERVICING OF AIR-CON PLANTS: 1 MAJOR SERVICE & 3 MINOR SERVICES ON QUARTERLY FORM FOR 2019/2020 AND PARTICLE COUNT TEST TWICE**

Enquiries for technical related matters:

Mr. S. Gaxa  
Tel. (031) 360 3468  
Fax. (031) 205 0207

**1. WORK TO BE DONE: -**

Service as per attached service schedule:

**NEW BLOCK:**

ACA 09-002A, ACA 09-002B, ACA15-001, ACA 14-002, ACA 8-003B, ACA 8-003A, ACA 16-001, CPI-001, IA1-001

**OTO:**

ACA9-002A; ACA9-002B; IA1-001; ACA14-002; ACA16-001

**COT & TRAUMA:**

ACA 14-002, ACA9-002A, ACA9-002B; ACA16-00; IA1-001, ACA10-002A, ACA10-002B

**NB: Company Sticker clearly showing date of the next service (Minor) must be visible**

	All materials used in this contract shall be that which is specified, or other approved.				
	Contractors are advised to visit site to acquaint themselves with the site and the layout of the institution as no claims on the grounds of ignorance of the locality/siting of the institution will be entertained later.				
	Contractors are informed that living on the institution premises during the contract is not allowed and arrangements for accommodation will have to be allowed for:				
<b>NB</b>	<b>A detailed work-plan including a safety plan must be submitted before starting a project. Plan to be reviewed on weekly basis by the Foreman, Artisan Superintendent, Engineering Service Manager &amp; the Responsible Contractor.</b>				
<b>Item</b>	<b>Description</b>	<b>Unit</b>	<b>Quantity</b>	<b>Rate</b>	<b>Total</b>
1	NEW BLOCK PLANT		1		
2	OTO PLANT		1		

3	COT & TRAUMA PLANT		1		
4.	AIR HANDLING CHILLER UNITS:				
	Duty Room Trauma		1		
	Card Office		1		
	Passage		1		
	Theater 4		1		
<b>NB</b>	<b>ALL PRIMARY, SECONDARY &amp; MEGA FILTERS MUST BE REPLACED ON MAJOR SERVICE: ENSURE MAKING PROVISION FOR PARTICLE COUNT TEST (6 MONTHLY) BEFORE CHANGING OF HIPO FILTERS AND AFTER CONDUCT OIL ANALYSIS &amp; GIVE REPORT</b>				


Requirement:

1. CIDB GRADE 3ME.
2. PROVEN RECORD OF EXPERIENCE IN THEATRE A/C'S ( REFERENCE LETTER FROM AN INSTITUTION OR INSTITUTIONS THAT YOU PROVIDED SERVICES PREVIOUSLY INCLUDING ORDER NUMBER OR NUMBERS )



Mr. S. Gaxa  
Electrical Foreman

Mr. S.V. Mbatha  
Chief Artisan



Mr. G.S. Dladla  
Engineering Service Manager