




## Quotation Advert

Opening Date: 2019-05-20   
Closing Date: 2019-06-03   
Closing Time: 11:00

### INSTITUTION DETAILS

Institution Name: King Edward VIII hospital   
Province: KwaZulu-Natal  
Department or Entity: Department of Health  
Division or section: Central Supply Chain Management  
Place where goods / services is required: KING EDWARD VIII HOSPITAL MAINTENANCE  
Date Submitted: 2019-05-15 

### ITEM CATEGORY AND DETAILS

Quotation Number: ZNQ  
KM 41119  
Item Category: Services   
Item Description: CARRY OUT CAIDFRIFIER HOT WATER PLANT SERVICE AS PER SCOPE  
\*QUOTES TO BE HANDED OUT AFTER SITE MEETING

Quantity (if supplies) 1

### COMPULSORY BRIEFING SESSION / SITE VISIT


Select Type: Compulsory Briefing Session   
Date: 2019-05-27   
Time: 11:00  
Venue: KING EDWARD VIII HOSPITAL OUTSIDE MAINTENANCE

QUOTES CAN BE COLLECTED FROM: KHULANI MTHEMBU

QUOTES SHOULD BE DELIVERED TO: KING EDWARD VIII HOSPITAL TENDOR BOX

### ENQUIRIES REGARDING THE ADVERT MAY BE DIRECTED TO:

Name: KHULANI MTHEMBU  
Email: KHULANI.MTHEMBU@KZNHEALTH.GOV.ZA  
Contact Number: 031 360 8448  
Finance Manager Name: MISS NOMONDE MCHUMF

Finance Manager Signature: 

No late quotes will be considered

Scope of work

Attend to DHWS 2-001a (Calorifiers hot water systems) service schedule on the following plants.

Calorifiers

- 1) Old POPD
- 2) Admin

NB

No person will be allowed to start work and any machine if spares are not all on site.

No person will be allowed to continue to proceed to next plant without the last plant worked on is complete.

No plant will be left stripped of any part.

All plants will be left fully functional and locked (HA-1 padlock to be supplied and installed should plant not have pad lock.)

All system pressure gauges applicable to system water pressure must be changed.

**PROVINCE OF KWAZULU-NATAL  
PREVENTIVE MAINTENANCE SCHEDULE**

TYPE OF SERVICE : HOT WATER SYSTEMS  
 SCHEDULE FOR : CALORIFIERS  
 SCHEDULE FREQUENCY :

REF :  
 CODE : HWB2-001a

INSTALLATION NAME:

REF :

SERVICE PROVIDER:

ORDER No.:

P.M. SERVICE			RUNNING REPAIRS (Apply for V.O. As applicable)				OTHER REPAIRS REQUIRED SUBMIT QUOTATION				
ITEM	INSTRUCTION: CHECK, ADJUST, CLEAN AS REQUIRED	IN ORDER	OTHER NON-SPECIFIED RUNNING REPAIRS DONE	TIME TAKEN	DESCRIPTION OF SPARES USED	QUANTITY		DESCRIPTION OF OTHER REPAIRS REQUIRED	EST. TIME REQ.	DESCRIPTION OF SPARES REQUIRED	QTY REQ
						EX SITE STOCK	EX FIRMS STOCK				
1.	Check heat exchanger lagging										
2.	Repair all leaks (heat exchanger and hot water storage circuit)										
3.	Replace safety valve on tank and on incoming line and set on correct pressure.										
4.	Check air vents (where applicable)										
5.	Remount all loose unsupported steam and water pipes applicable to plant.										
6.	Replace steam traps, strainers and site glasses.										
7.	Replace SB valve and sa128 temp controller if not working.										
8.	Replace non-working pressure and temperature gauges.										
9.	Replace all steam isolating valves with spirax steam shut off valves applicable to plant.										
10.	Replace PRV valves on main incoming steam line and set to 2 bars.										
	<b>TO BE CARRIED OUT ON ANNUAL SERVICE</b>										



**NOTE THE FOLLOWING:**

- a) Heat exchanger (kW) .....
- b) No. of heat exchangers .....
- c) Make of heat exchangers .....
- d) No. of air vents .....

I CERTIFY THAT THE SPECIFIED SERVICE WAS CARRIED OUT						OFFICIAL STAMP:	
NAME OF SERVICEMAN (BLOCK LETTERS):				SIGNATURE:			
NAME/S OF ASSISTANT/S: SEMI SKILLED:							
NAME/S OF ASSISTANT/S: UNSKILLED:							
COMPANY NAME (BLOCK LETTERS):						NAME OF RESPONSIBLE OFFICIAL ON SITE:	
TIME IN:		TIME OUT:		TIME ON SITE:		DATE:	
FROM:	TO:	KM:	TO:	KM:	TOTAL KM:	SIGNATURE:	