

DIRECTORATE:

Townhill Office Park,35 Hyslop Road,Block 1 P/ BAG X 9051 Pietermaritzburg 3201 Tel: 033 940 2526 Email: Ernest.Zulu@kznhealth.gov.za

Infrastructure Development

AMENDMENT

Date: 28 February 2024	File No:

SUBJECT: WENTWORTH EMS BASE: GENERATOR REPLACEMENT ZNB 5168-2024-H: SITE BRIEFING AMENDMENTS		
<u>Page</u>	<u>Item</u>	
<u>Number</u>	<u>Number</u>	<u>Description Amendment</u>
		This page is to be replaced by the Document "1. Wentworth EMS Base - Generator
56	-	Replacement ZNB 5186 Price Page 56" which has been uploaded onto the website.
		The following pages are to be replaced by the Document "2. Wentworth EMS Base -
		Generator Replacement ZNB 5186 BOQ and Price Page 111-115" which has been uploaded
111-115		onto the website.

General:

- 1. The bill of quantities MUST be read in conjunction with "2. Annexure 10 Project Specifications Wentworth EMS Base Generator Replacement" which has been uploaded to the website.
- 2. The Contractor is to bid for and <u>OUTDOOR canopy set</u> and no building is required as was discussed at the site briefing. This is to ensure <u>uniformity and fair pricing</u> for all contractors.
- 3. Kindly take special note of all items in BOLD and HIGHLIGHTED in yellow.
- 4. There are a total of 6 documents uploaded to the website for amendments including this document.
- 5. Due to the critical nature of this installation, ONLY genuine and accredited DIESEL GENERATOR SET MANUFACTURERS / ASSEMBLERS with Local 24 hour support and IN HOUSE maintenance facilities will be considered.
- 6. When pricing this document, allowance must be made for the installation to be carried out after hours and / or over a weekend at a time suitable to the KZN Department of Health's institution. This will also include provision for a portable loan unit and LV panel during installation.

Kind Regards,

J. Pillay

Electrical Engineer - eThekwini Management Hub

28 February 2024